



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**10055-48-3291**  
State Number  
**24566**

EQUIPMENT INSPECTED

State Number: <b>24566</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2000	Manuf: THYSSEN KRUPP	Speed: 55
Landings: 3	Installed: 02/21/2007	Rope Size: 0
Volts: 230	Complied:	Entrances: 1
OWNER	OCCUPANT	
CROW CREEK BLDG #13	CROW CREEK - BLDG #13	
395 S CROW CREEK DRIVE	395 S CROW CREEK DRIVE	
CALABASH, NC, 28467	CALABASH, NC, 28467	

INSPECTION INFORMATION

Inspection Date 02/24/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.27.1.1.2 Put the in car emergency telephone in proper working order.

Items must be corrected by: 03/06/2010

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CROW CREEK BLDG #13  
395 S CROW CREEK DRIVE  
CALABASH, NC, 28467