



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10056-48-5421
State Number
H1321

EQUIPMENT INSPECTED

State Number: H1321	Type of Unit: Hand Lift	Floor to Floor: 1 to 2
Capacity: 750	Manuf: THYSSEN KRUPP	Speed: 15
Landings: 2	Installed: 10/04/2002	Rope Size: 0
Volts: 115	Complied: 10/04/2002	Entrances: 2
OWNER	OCCUPANT	
WINDSOR METHODIST CHURCH	WINDSOR METHODIST CHURCH	
6292 OLD FAYETTEVILLE RD.	12880 NC HWY 242	
AMMON, NC, 28441	AMMON, NC, 28441	

INSPECTION INFORMATION

Inspection Date 02/25/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BLADEN
-------------------------------	----------------------------	---------------------------------	--------------------------	------------------

9

VIOLATIONS

5.1.21.1	Put the in car alarm bell in working order.
8.6.4.7.1	Clean the elevator pit.

Items must be corrected by: 03/27/2010

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

WINDSOR METHODIST CHURCH
6292 OLD FAYETTEVILLE RD.
AMMON, NC, 28441