N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10062-4-4019
State Number
14194

EQUIPMENT INSPECTED

State Number: **14194**	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 07/25/1991	Rope Size: 0
Volts: 208	Complied: 07/25/1991	Entrances: 1

OWNER
ALEXANDER COUNTY SCHOOLS
700 LILEDOUN ROAD
TAYLORSVILLE, NC, 28681

OCCUPANT
BETHLEHEM ELEMENTARY SCHOOL
7900 N.C. HWY 127
TAYLORSVILLE, NC, 28681

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
03/03/2010	Routine	Re-issued	4 - Henegar	ALEXANDER

2

VIOLATIONS

n/a No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Alexander Schools # 828-635-8248 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
ALEXANDER COUNTY SCHOOLS
700 LILEDOUN ROAD
TAYLORSVILLE, NC, 28681