



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10064-24-0850
State Number
23783

EQUIPMENT INSPECTED

State Number: 23783	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: IECA	Speed: 100
Landings: 3	Installed: 03/13/2006	Rope Size: .
Volts: 208	Complied:	Entrances: 1

OWNER

ASHEVILLE BOARD OF REALTORS
37 MONTFORD AVE
ASHEVILLE, NC, 28801

OCCUPANT

ASHEVILLE BOARD OF REALTORS
37 MONTFORD AVE
ASHEVILLE, NC, 28801

INSPECTION INFORMATION

Inspection Date 03/05/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 24 - Moore	County BUNCOMBE	11 B
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

- 8.6.4.13.1[a] Properly maintain hoist way door interlocks or mechanical locks and electric contacts. Check for alignment of clutch to release rollers. Door very loose in clutch at floor . Gap too wide?
- 2.14.1.5.1 Secure the car top emergency exit. Reattach the safety chair and lock the escape hatch.
- 8.11.3.1.6 Provide documentation of the annual fire alarm initiating device test associated with the elevator recall. Make available to the authority having jurisdiction.

Items must be corrected by: 04/04/2010

Elevator Name: ELEVATOR # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Left with office

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ASHEVILLE BOARD OF REALTORS
37 MONTFORD AVE
ASHEVILLE, NC, 28801