N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10068-36-3477
State Number
21988

EQUIPMENT INSPECTED

State Number: **21988**
Capacity: 2100
Landings: 2
Volts: 208

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 10/16/2003
Complied: 10/16/2003

Floor to Floor: 1 to 2
Speed: 80
Rope Size: 0
Entrances: 1

OWNER
MEBANE POLICE STATION
116 W CENTER STREET
MEBANE, NC, 27302

OCCUPANT
MEBANE POLICE STATION
116 W CENTER STREET
MEBANE, NC, 27302

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
03/09/2010	Routine	Re-issued	36 - Kirkman	ALAMANCE

1

VIOLATIONS

No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: office

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
MEBANE POLICE STATION
116 W CENTER STREET
MEBANE, NC, 27302