N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10069-24-029
State Number
16683

EQUIPMENT INSPECTED

State Number: **16683**
Capacity: 2000
Landings: 3
Volts: 208

Type of Unit: Passenger
Manuf: KONE
Installed: 09/16/1997
Complied: 10/31/1997

Floor to Floor: 1 to 3
Speed: 125
Rope Size:
Entrances: 1

OWNER
32 BROADWAY CONDO ASSOC
32 BROADWAY ST UNIT 100
ASHEVILLE, NC, 28801

OCCUPANT
JENKINS BLDG
32 BROADWAY ST
ASHEVILLE, NC, 28801

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
03/10/2010	Routine	Re-issued	24 - Moore	BUNCOMBE	11 B

VIOLATIONS

2.27.1.1.2	Put the in car emergency telephone in proper working order. 2ND NOTICE!!!!!!
2.14.7.1.3	Put the in car emergency light in working order. Goes out when bell is pushed.
8.6.10.1	Perform a monthly firefighters Phase 1 and 2 test with the key switches and a minimum one floor run. Document test results with availability to inspector. 2ND NOTICE!!!!!!!
8.11.3.2.1	Perform the annual relief valve test. Last date 7/08
N.C.S.B.C.	Provide proper fire rating of the elevator equipment room. 2ND NOTICE!!!!!!
8.11.3.1.6	Provide documentation of the annual fire alarm initiating device test associated with the elevator recall. 2ND NOTICE!!!!!!!!!

Items must be corrected by: 04/09/2010

Elevator Name: ELEVATOR # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Left with Beauty Shop 2nd floor for John Ewing/Manager

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
32 BROADWAY CONDO ASSOC
32 BROADWAY ST UNIT 100
ASHEVILLE, NC, 28801