



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10069-4-4762
State Number
8022

EQUIPMENT INSPECTED

State Number: 8022	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 2	Installed: 08/06/1975	Rope Size: 0
Volts: 220	Complied: 08/06/1975	Entrances: 1
OWNER	OCCUPANT	
AVERY COUNTY	AVERY COUNT COURTHOUSE	
P.O. BOX 640	200 MONTEZUMA STREET	
NEWLAND, NC, 28657	NEWLAND, NC, 28657	

INSPECTION INFORMATION

Inspection Date 03/10/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 4 - Henegar	County AVERY
-------------------------------	----------------------------	---------------------------------	--------------------------	-----------------

6

VIOLATIONS

8.11.3.2.1 Perform the annual relief valve test

Items must be corrected by: 04/09/2010

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Avery County # 828-387-0072

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

AVERY COUNTY
P.O. BOX 640
NEWLAND, NC, 28657