



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**10096-48-3448**  
State Number  
**26188**

EQUIPMENT INSPECTED

State Number: <b>26188</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: SCHINDLER	Speed: 125
Landings: 2	Installed: 12/22/2008	Rope Size:
Volts: 480	Complied: 12/22/2008	Entrances: 2
OWNER	OCCUPANT	
BRUNSWICK COMM COLLEGE	BCC ATHLETIC & AQUATICS CENTER	
PO BOX 30	50 COLLEGE ROAD	
SUPPLY, NC, 28462	SUPPLY, NC, 28462	

INSPECTION INFORMATION

Inspection Date 04/06/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.13.1[f] Properly maintain hangers, tracks, door rollers, up-thrusts, and door safety retainers, where required. 2ND. FL. CAR GATE STICKING WHILE OPENING.

Items must be corrected by: 04/16/2010

Elevator Name: #1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: HUGE

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BRUNSWICK COMM COLLEGE  
PO BOX 30  
SUPPLY, NC, 28462