N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10096-48-3660
State Number
17403

EQUIPMENT INSPECTED

State Number: **17403**
Capacity: 2100
Landings: 2
Volts: 460

Type of Unit: Passenger
Manuf: US ELEVATOR
Installed: 07/10/1998
Complied: 07/16/1998

Floor to Floor: 1 to 2
Speed: 125
Rope Size:
Entrances: 1

OWNER
BRUNSWICK COMM COLLEGE
PO BOX 30
SUPPLY, NC, 28462

OCCUPANT
BRUNSWICK COMMUNITY COLLEGE
50 COLLEGE RD. HWY. 17 BYPASS
SUPPLY, NC, 28462

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
04/06/2010	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

5.1.21.1 Put the in car alarm bell in working order.

Items must be corrected by: 04/16/2010

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: HUGE

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
BRUNSWICK COMM COLLEGE
PO BOX 30
SUPPLY, NC, 28462