



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10096-48-5580
State Number
H1944

EQUIPMENT INSPECTED

State Number: H1944	Type of Unit: Hand Lift	Floor to Floor: 1 to 2
Capacity: 750	Manuf: GARAVENTA	Speed: 10
Landings: 2	Installed: 05/14/2008	Rope Size:
Volts: 120	Complied:	Entrances: 2
OWNER	OCCUPANT	
BRUNSWICK COMMUNITY COLLEGE	ODELL WILLIAMSON AUDITORIUM	
50 COLLEGE ROAD	50 COLLEGE ROAD	
SUPPLY, NC, 28462	SUPPLY, NC, 28462	

INSPECTION INFORMATION

Inspection Date 04/06/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

n/a No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: HUGE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BRUNSWICK COMMUNITY COLLEGE
50 COLLEGE ROAD
SUPPLY, NC, 28462