



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10098-16-3246
State Number
N7.16

EQUIPMENT INSPECTED

State Number: N7.16	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 1200	Manuf: WESTBROOK	Speed: 100
Landings: 4	Installed: 01/24/1978	Rope Size: 5/8
Volts: 220	Complied: 01/24/1978	Entrances: 1

OWNER

MARY SUE FRANKLIN
106 W. MAIN ST.
WASHINGTON, NC, 27889

OCCUPANT

OASIS HAIR SALON
106 W MAIN ST
WASHINGTON, NC, 27889

INSPECTION INFORMATION

Inspection Date 04/08/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

7

VIOLATIONS

- 8.6.1.6.2 All parts of the machinery and equipment requiring lubrication shall be lubricated with lubricants equivalent manufacturers recommendations properly fill Machine with fluid
- 8.11.2.2.2 Perform an annual no load safety test and provide proper tags.

Items must be corrected by: 05/08/2010

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Mary Sue Franklin

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

MARY SUE FRANKLIN
106 W. MAIN ST.
WASHINGTON, NC, 27889