



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10105-36-2543
State Number
5813

EQUIPMENT INSPECTED

State Number: 5813	Type of Unit: Freight	Floor to Floor: 1 to 2
Capacity: 8000	Manuf: WESTBROOK	Speed: 100
Landings: 2	Installed: 04/08/1968	Rope Size:
Volts: 550	Complied: 10/11/1991	Entrances: 1
OWNER	OCCUPANT	
ELITE WAREHOUSE LLC	ELITE WAREHOUSE LLC	
3000 RDU CENTER DRIVE STE 102	300 PARKER ST	
MORRISVILLE, NC, 27560	GRAHAM, NC, 27253	

INSPECTION INFORMATION

Inspection Date 04/15/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

8.6.4.13.1	Take steps to maintain and provide proper operation of the door system escutcheons.
8.1.1	Provide the machine room keys on the premises.
8.11.2.2.2	Perform the annual no load safety test
2.11.11.5.2	PULL METAL IN ON LEFT SIDE OF ELEVATOR WALL

Items must be corrected by: 05/15/2010

Elevator Name: saurabh wag

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: SAURABH W

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELITE WAREHOUSE LLC
3000 RDU CENTER DRIVE STE 102
MORRISVILLE, NC, 27560