



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10105-36-4364
State Number
548

EQUIPMENT INSPECTED

State Number: 548	Type of Unit: Freight	Floor to Floor: 1 to 3
Capacity: 4000	Manuf: OTIS	Speed: 100
Landings: 3	Installed: 12/03/1945	Rope Size: 1/2
Volts: 550	Complied: 10/31/1958	Entrances: 1
OWNER ELITE WAREHOUSE LLC 3000 RDU CENTER DRIVE STE 102 MORRISVILLE, NC, 27560		OCCUPANT ELITE WAREHOUSE LLC 300 E PARKER ST GRAHAM, NC, 27253

INSPECTION INFORMATION

Inspection Date 04/15/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

8.11.2.3	Perform a 5 year full load safety test
2.14.4.7	Replace or repair the damaged car gate.

Items must be corrected by: 05/15/2010

Elevator Name: BUILDING # B

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: SAURABH WAGH

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELITE WAREHOUSE LLC
3000 RDU CENTER DRIVE STE 102
MORRISVILLE, NC, 27560