N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10105-48-0327
State Number
25786

EQUIPMENT INSPECTED

State Number: **25786**	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 4000	Manuf: SCHINDLER	Speed: 150
Landings: 3	Installed: 08/06/2008	Rope Size:
Volts: 480	Complied: 08/06/2008	Entrances: 2

OWNER
BRUNSWICK CO COURTHOUSE OPERATION SERVIC
P.O. BOX 249
BOLIVIA, NC, 28422

OCCUPANT
BRUNSWICK COUNTY ADMIN BLDG
30 GOVERNMENT CENTER DRIVE
BOLIVIA, NC, 28422

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
04/15/2010	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

8.11.2.2.2	Perform the annual no load safety test

Items must be corrected by: 05/15/2010

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: JAMES

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
BRUNSWICK CO COURTHOUSE OPERATION SERVIC
P.O. BOX 249
BOLIVIA, NC, 28422