



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**10110-36-0411**  
State Number  
**11988**

EQUIPMENT INSPECTED

State Number: <b>11988</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 11/12/1986	Rope Size:
Volts: 208	Complied: 12/08/1986	Entrances: 1
OWNER	OCCUPANT	
TAR HEEL DRUG COMPANY	TAR HEEL DRUG COMPANY	
316 S MAIN ST	316 S MAIN ST	
GRAHAM, NC, 27253	GRAHAM, NC, 27253	

INSPECTION INFORMATION

Inspection Date 04/20/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

2.14.7.1.3	Put the in car emergency light in working order.
8.6.4.9	Clean the elevator car top.
8.6.4.7.1	Clean the elevator pit.
8.6.1.6.5	Provide a class "ABC" fire extinguisher in the machine room or control space convenient to the access door.
5.1.21.1	Put the in car alarm bell in working order.

Items must be corrected by: 05/20/2010

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: justin

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

TAR HEEL DRUG COMPANY  
316 S MAIN ST  
GRAHAM, NC, 27253