



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10118-36-1164
State Number
17543

EQUIPMENT INSPECTED

State Number: 17543	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 135
Landings: 3	Installed: 05/06/1998	Rope Size:
Volts: 208	Complied: 05/07/1998	Entrances: 1
OWNER	OCCUPANT	
GUNATIT HOSPITALITY	HAMPTON INN	
1602 MECHANICAL BLVD	105 SPRING FOREST DR	
GARNER, NC, 27529	MEBANE, NC, 27302	

INSPECTION INFORMATION

Inspection Date 04/28/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

8.6.10.1	Update the monthly fire service log.
8.6.4.3.4	Take steps to remove rough vibration between the second and third floor. Second notice!!!!!!!

Items must be corrected by: 05/28/2010

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: office

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

GUNATIT HOSPITALITY
1602 MECHANICAL BLVD
GARNER, NC, 27529