



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10119-36-133
State Number
8573

EQUIPMENT INSPECTED

State Number: 8573	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 04/06/1976	Rope Size:
Volts: 460	Complied: 04/06/1976	Entrances: 1
OWNER	OCCUPANT	
ALAMANCE-BURLINGTON SCHOOL SYSTEM	ANDREWS ELEMENTARY SCHOOL	
1712 VAUGHN RD	2630 BUCKINGHAM RD	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 04/29/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: office

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALAMANCE-BURLINGTON SCHOOL SYSTEM
1712 VAUGHN RD
BURLINGTON, NC, 27215