N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10137-16-1779
State Number
N7.1

EQUIPMENT INSPECTED

State Number: **N7.1**	Type of Unit: Freight	Floor to Floor: B to 3
Capacity: 1500	Manuf: WESTBROOK	Speed: 100
Landings: 5	Installed: 05/21/1975	Rope Size: 5/8
Volts: 220	Complied: 05/21/1975	Entrances: 2

OWNER	OCCUPANT
NORMAN MANNING	PHILLIPS WRIGHT FURNITURE CO.
246 W MAIN ST.	246 W MAIN ST
WASHINGTON, NC, 27889	WASHINGTON, NC, 27889

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
05/17/2010	Routine	Re-issued	16 - Moore	BEAUFORT

7

VIOLATIONS

8.6.4.10.1[c] Winding-drum driving-machines with 1:1 roping, if of the babbitted rope socket type, shall be resocketed, or for other type of fastenings, replaced or moved on the rope to a point above the existing fastening at the car ends

8.11.2.2.2 Perform an annual no load safety test and provide proper tags.

Items must be corrected by: 06/16/2010

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Fredrick Switzer

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
NORMAN MANNING
246 W MAIN ST.
WASHINGTON, NC, 27889