



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10137-16-2413
State Number
23874

EQUIPMENT INSPECTED

State Number: 23874	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 80
Landings: 2	Installed: 07/17/2006	Rope Size: 0
Volts: 208	Complied: 07/20/2006	Entrances: 1
OWNER	OCCUPANT	
BAY LEAF PLANTATION SENIOR	BAY LEAF PLANTATION SENIOR	
1120 COWELL FARM ROAD	1120 COWELL FARM ROAD	
WASHINGTON, NC, 27889	WASHINGTON, NC, 27889	

INSPECTION INFORMATION

Inspection Date 05/17/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

7

VIOLATIONS

8.6.1.6.5 Provide the required fire extinguisher in the machine room.

Items must be corrected by: 06/16/2010

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Kimberly Stanley

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BAY LEAF PLANTATION SENIOR
1120 COWELL FARM ROAD
WASHINGTON, NC, 27889