



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**10145-48-536**  
State Number  
**24502**

#### EQUIPMENT INSPECTED

State Number: <b>24502</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 06/27/2007	Rope Size: 0
Volts: 480	Complied: 06/27/2007	Entrances: 1
OWNER	OCCUPANT	
ST JAMES SQUARE OF WILMINGTON	ST JAMES OFFICE BUILDING	
1508 MILITARY CUTOFF RD	4330 SOUTHPORT SUPPLY ROAD	
WILMINGTON, NC, 28403	SOUTHPORT, NC, 28461	

#### INSPECTION INFORMATION

Inspection Date 05/25/2010	Type Inspection Routine	Certificate Status Not Issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	----------------------------------	--------------------------	---------------------

10

#### VIOLATIONS

2.27.1.1.2 Put the in car emergency telephone in proper working order.

8.1.1[c] Keys shall be kept on the premises in a location readily accessible to the personnel in the assigned group, but not where they are accessible to the general public. NO ACCESS TO MOTOR ROOM.

N/A PARTIAL INSP.

Items must be corrected by: 06/14/2010

Elevator Name: BLDG. 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ST JAMES SQUARE OF WILMINGTON  
1508 MILITARY CUTOFF RD  
WILMINGTON, NC, 28403