



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10146-48-5252
State Number
24502

EQUIPMENT INSPECTED

State Number: 24502	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 06/27/2007	Rope Size: 0
Volts: 480	Complied: 06/27/2007	Entrances: 1

OWNER

ST JAMES SQUARE OF WILMINGTON
1508 MILITARY CUTOFF RD
WILMINGTON, NC, 28403

OCCUPANT

ST JAMES OFFICE BUILDING
4330 SOUTHPORT SUPPLY ROAD
SOUTHPORT, NC, 28461

INSPECTION INFORMATION

Inspection Date 05/26/2010	Type Inspection Compliance	Certificate Status Issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	-------------------------------	------------------------------	--------------------------	---------------------

10

VIOLATIONS

- 8.11.2.2.2 Perform the annual no load safety test
- 8.6.1.6.5 Provide a class "ABC" fire extinguisher in the machine room or control space convenient to the access door. EXT. ON FLOOR.

Items must be corrected by: 06/25/2010

Elevator Name: BLDG. 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ST JAMES SQUARE OF WILMINGTON
1508 MILITARY CUTOFF RD
WILMINGTON, NC, 28403