



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10161-48-226
State Number
24780

EQUIPMENT INSPECTED

State Number: 24780	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: TKE	Speed: 135
Landings: 3	Installed: 06/27/2007	Rope Size:
Volts: 208	Complied: 06/27/2007	Entrances: 1

OWNER
STATION DEVELOPMENT CORP.
5001 UNIT J O'QUINN BLVD.
SOUTHPORT, NC, NC, 28461

OCCUPANT
SOUTH HARBOR
4132 VANESSA DRIVE
OAK ISLAND, NC, 28429

INSPECTION INFORMATION

Inspection Date 06/10/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

- 2.27.1.1.2 Put the in car emergency telephone in proper working order.
8.6.8.9 Signs. Caution signs shall be provided. Damaged or missing signs shall be replaced. MISSING SIGNS ON ALL FLOORS.

Items must be corrected by: 06/20/2010

Elevator Name: # 2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

STATION DEVELOPMENT CORP.
5001 UNIT J O'QUINN BLVD.
SOUTHPORT, NC, NC, 28461