



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10165-36-2447
State Number
11235

EQUIPMENT INSPECTED

State Number: **11235**

Capacity: 4000

Landings: 4

Volts: 460

Type of Unit: Passenger

Manuf: SOUTHERN

Installed: 05/20/1986

Complied: 06/24/1986

Floor to Floor: B to 3

Speed: 150

Rope Size:

Entrances: 1

OWNER

ALAMANCE CO. JAIL

ELM STREET

GRAHAM, NC, 27253

OCCUPANT

ALAMANCE CO. JAIL

ELM STREET

GRAHAM, NC, 27253

INSPECTION INFORMATION

Inspection Date
06/14/2010

Type Inspection
Routine

Certificate Status
Re-issued

Inspector
36 - Kirkman

County
ALAMANCE

1

VIOLATIONS

No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: OFFICE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALAMANCE CO. JAIL
ELM STREET
GRAHAM, NC, 27253