



INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
www.nclabor.com/elevator.htm  
919-707-7927

Report Number  
**10165-50-2229**  
State Number  
**24950**

EQUIPMENT INSPECTED

State Number: **24950**                      Type of Unit: Passenger                      Floor to Floor: 1 to 3  
Capacity: 3500                              Manuf: THYSSEN KRUPP                      Speed: 125  
Landings: 2                                  Installed: 06/19/2007                      Rope Size: 0  
Volts: 480                                    Complied:                                      Entrances: 1

OWNER  
CITY OF CHARLOTTE CATS FACILITIES  
600 E. 4TH ST  
CHARLOTTE, NC, 28202

OCCUPANT  
CATS LIGHT RAIL SOUTH BLVD  
3200 S. BLVD  
CHARLOTE, NC, 28217

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
06/14/2010	Routine	Re-issued	50 - Offe	MECKLENBURG	60 B

VIOLATIONS

- 2.2.5.1 Put the pit lights in proper working order.
- 8.6.5.7 Provide an oil usage log.
- 8.6.10.1 Update the monthly fire service log.
- 8.11.2.2.2 Perform an annual no load safety test and provide proper tags.

Items must be corrected by: 07/14/2010

Elevator Name: ELEVATOR # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Brent Roland 704-432-5008

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CITY OF CHARLOTTE CATS FACILITIES  
600 E. 4TH ST  
CHARLOTTE, NC, 28202