



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10167-16-4816
State Number
17645

EQUIPMENT INSPECTED

State Number: 17645	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 3	Installed: 11/02/1998	Rope Size: 0
Volts: 208	Complied: 03/10/2005	Entrances: 1
OWNER	OCCUPANT	
WYNNE VIEW INC	WYNN VIEW OFFICE BLDG	
PO BOX 115	104 W WATER ST	
BELHAVEN, NC, 27810	BELHAVEN, NC, 27810	

INSPECTION INFORMATION

Inspection Date 06/16/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

7

VIOLATIONS

n/a No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Marty the Director

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

WYNNE VIEW INC
PO BOX 115
BELHAVEN, NC, 27810