



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10168-48-1991
State Number
6961

EQUIPMENT INSPECTED

State Number: 6961	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 08/05/1971	Rope Size:
Volts: 480	Complied: 08/05/1971	Entrances: 1

OWNER

ELIZABETHTOWN MIDDLE SCHOOL
P O BOX 639
ELIZABETHTOWN, NC, 28327

OCCUPANT

ELIZABETHTOWN MIDDLE SCHOOL
HWY 701 SOUTH
ELIZABETHTOWN, NC, 28337

INSPECTION INFORMATION

Inspection Date 06/17/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BLADEN
-------------------------------	----------------------------	---------------------------------	--------------------------	------------------

9

VIOLATIONS

8.6.1.6.5 Provide a class "ABC" fire extinguisher in the machine room or control space convenient to the access door.

Items must be corrected by: 07/07/2010

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: WILLIAM

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELIZABETHTOWN MIDDLE SCHOOL
P O BOX 639
ELIZABETHTOWN, NC, 28327