



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10181-17-2241
State Number
23443

EQUIPMENT INSPECTED

State Number: 23443	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 95
Landings: 2	Installed: 12/07/2005	Rope Size:
Volts: 208	Complied: 01/05/2006	Entrances: 1

OWNER

ALLERGY PARTNERS
390 SOUTH FRENCH BROAD AVE
ASHEVILLE, NC, 28801

OCCUPANT

1985 HENDESONVILLE RD. LOT 4
1985 HENDERSONVILLE RD
ASHEVILLE, NC, 28803

INSPECTION INFORMATION

Inspection Date 06/30/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

- 8.1.1[c] Keys shall be kept on the premises in a location readily accessible to the personnel in the assigned group, but not where they are accessible to the general public.
- 8.1.1 Keys used to access or operate elevator, escalator, moving walk, dumbwaiter, and material lift equipment shall conform to the following:

Items must be corrected by: 07/30/2010

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Lauria

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALLERGY PARTNERS
390 SOUTH FRENCH BROAD AVE
ASHEVILLE, NC, 28801