



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10188-48-1160
State Number
23971

EQUIPMENT INSPECTED

State Number: 23971	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2000	Manuf: THYSSEN KRUPP	Speed: 55
Landings: 3	Installed: 05/17/2006	Rope Size: 0
Volts: 230	Complied: 05/17/2006	Entrances: 1

OWNER

CROW CREEK CONDO
9300 OCEAN HWY 17W
CALABASH, NC, 28467

OCCUPANT

CROW CREEK CONDO #9
235 WOODLANDS WAY
CALABASH, NC, 28467

INSPECTION INFORMATION

Inspection Date 07/07/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.1.6.5 Provide a class "ABC" fire extinguisher in the machine room or control space convenient to the access door. EXT. ON FLOOR

Items must be corrected by: 07/27/2010

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CROW CREEK CONDO
9300 OCEAN HWY 17W
CALABASH, NC, 28467