



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**10188-48-388**  
State Number  
**21687**

EQUIPMENT INSPECTED

State Number: <b>21687</b>	Type of Unit: Passenger	Floor to Floor: . to .
Capacity: 2100	Manuf: RENAME	Speed: 0
Landings: 0	Installed: 05/29/2003	Rope Size: .
Volts: 0	Complied: 06/11/2003	Entrances: 0
OWNER	OCCUPANT	
CROW CREEK	CROW CREEK CONDO	
250 CROW CREEK DRIVE	250 S. CROW CREEK DR.	
CALABASH, NC, 28469	CALABASH, NC, 28469	

INSPECTION INFORMATION

Inspection Date 07/07/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.7.1 Clean the elevator pit. COB WEBS

Items must be corrected by: 07/27/2010

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CROW CREEK  
250 CROW CREEK DRIVE  
CALABASH, NC, 28469