



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10188-48-5197
State Number
23970

EQUIPMENT INSPECTED

State Number: 23970	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2000	Manuf: THYSSEN KRUPP	Speed: 55
Landings: 3	Installed: 03/29/2006	Rope Size: 0
Volts: 230	Complied:	Entrances: 1
OWNER	OCCUPANT	
CROW CREEK CONDO	CROW CREEK CONDO #8	
9300 OCEAN HWY 17 WEST	240 WOODLANDS WAY	
CALABASH, NC, 28497	CALABASH, NC, 28467	

INSPECTION INFORMATION

Inspection Date 07/07/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.13.1[k] Properly maintain door closers, where required. REPAIR MOTOR ROOM DOOR TO CLOSE & LOCK ON ITS OWN.

Items must be corrected by: 07/27/2010

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CROW CREEK CONDO
9300 OCEAN HWY 17 WEST
CALABASH, NC, 28497