



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10193-48-1462
State Number
22316

EQUIPMENT INSPECTED

State Number: 22316	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 65
Landings: 3	Installed: 10/20/2004	Rope Size:
Volts: 240	Complied: 11/04/2004	Entrances: 1
OWNER	OCCUPANT	
CROW CREEK	CROW CREEK CONDOS #3	
9300 OCEAN HWY 17, WEST	290 WOODLANDS WAY, SW	
CALABASH, NC, 28467	CALABASH, NC, 28467	

INSPECTION INFORMATION

Inspection Date 07/12/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.27.1.1.2	Put the in car emergency telephone in proper working order.
8.6.4.7.1	Clean the elevator pit. COB WEBS

Items must be corrected by: 08/01/2010

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CROW CREEK
9300 OCEAN HWY 17, WEST
CALABASH, NC, 28467