



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10196-48-2756
State Number
17723

EQUIPMENT INSPECTED

State Number: 17723	Type of Unit: Passenger	Floor to Floor: G to 2
Capacity: 3000	Manuf: OTIS	Speed: 125
Landings: 4	Installed: 06/30/1998	Rope Size:
Volts: 208	Complied: 06/30/1998	Entrances: 1
OWNER	OCCUPANT	
ISLANDER INN	ISLANDER INN	
57 W FIRST ST	57 W FIRST ST	
OCEAN ISLE, NC, 28469	OCEAN ISLE, NC, 28469	

INSPECTION INFORMATION

Inspection Date 07/15/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.7.4 Remove the water from the pit floor.

Items must be corrected by: 08/04/2010

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: JUSTIN

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ISLANDER INN
57 W FIRST ST
OCEAN ISLE, NC, 28469