



INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10200-46-1243
State Number
5938

EQUIPMENT INSPECTED

State Number: **5938** Type of Unit: Passenger Floor to Floor: 1 to 6
Capacity: 2000 Manuf: SCHINDLER Speed: 300
Landings: 6 Installed: 03/27/1968 Rope Size: 1/2
Volts: 208 Complied: 04/08/1968 Entrances: 1

OWNER
ANTHONY ALLEN PROP. MGR.
PO BOX 10810
RALEIGH, NC, 27605

OCCUPANT
FIRST RALEIGH TELEX
234 FAYETTEVILLE ST
RALEIGH, NC, 27601

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
07/19/2010	Routine	Re-issued	46 - Jones	WAKE	92 D

VIOLATIONS

5.1.21.1 Put the in car alarm bell in working order. (2nd notice)

Items must be corrected by: 08/18/2010

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: AAP

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ANTHONY ALLEN PROP. MGR.
PO BOX 10810
RALEIGH, NC, 27605