



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10201-48-2918
State Number
23068

EQUIPMENT INSPECTED

State Number: 23068	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 3500	Manuf: OTIS	Speed: 100
Landings: 4	Installed: 09/09/2005	Rope Size:
Volts: 240	Complied: 09/13/2005	Entrances: 2
OWNER	OCCUPANT	
WATERWAY LANDING HOMEOWNERS ASS.	WATERWAY LANDING CONDOS	
1135 PARK ROAD	1135 PARK ROAD	
SUNSET BEACH, NC, 28468	SUNSET BEACH, NC, 28468	

INSPECTION INFORMATION

Inspection Date 07/20/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.27.1.1.2 Put the in car emergency telephone in proper working order.

Items must be corrected by: 07/30/2010

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

WATERWAY LANDING HOMEOWNERS ASS.
1135 PARK ROAD
SUNSET BEACH, NC, 28468