



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10202-48-4974
State Number
26864

EQUIPMENT INSPECTED

State Number: 26864	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2000	Manuf: TKE	Speed: 55
Landings: 3	Installed: 07/21/2009	Rope Size:
Volts: 230	Complied: 07/21/2009	Entrances: 1
OWNER	OCCUPANT	
INLET VIEW BAR & GRILL	INLET VIEW BAR & GRILL	
1039 HIGHTPOINT AVE SW	1800 VILLAGE POINT ROAD	
CALABASH, NC, 28467	SHALLOTTE, NC, 28470	

INSPECTION INFORMATION

Inspection Date 07/21/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.9 Clean the elevator car top. REMOVE WEIGHTS OFF TOP OF CAR

Items must be corrected by: 07/31/2010

Elevator Name: #1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: SAMANTHA HUGES

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

INLET VIEW BAR & GRILL
1039 HIGHTPOINT AVE SW
CALABASH, NC, 28467