



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10202-7-1840
State Number
11204

EQUIPMENT INSPECTED

| | | |
|----------------------------|---------------------------|------------------------|
| State Number: 11204 | Type of Unit: Passenger | Floor to Floor: 1 to 3 |
| Capacity: 2100 | Manuf: THYSSEN KRUPP | Speed: 100 |
| Landings: 3 | Installed: 07/25/1985 | Rope Size: |
| Volts: 220 | Complied: 07/25/1985 | Entrances: 1 |
| OWNER | OCCUPANT | |
| THE GREYSTONE INN | THE GREYSTONE INN | |
| 2663 ROARING GAP DR. | 2663 ROARING GAP DR. | |
| ROARING GAP NC, NC, 28668 | ROARING GAP NC, NC, 28668 | |

INSPECTION INFORMATION

| | | | | |
|-------------------------------|----------------------------|---------------------------------|--------------------------|---------------------|
| Inspection Date 07/21/2010 | Type Inspection Routine | Certificate Status Re-issued | Inspector 7 - Hoffman | County ALLEGHANY |
|-------------------------------|----------------------------|---------------------------------|--------------------------|---------------------|

3

VIOLATIONS

8.11.3.2.1 PERFORM THE ANNUAL RELIEF VALVE TEST

Items must be corrected by: 08/20/2010

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: STEVE PLUMBER 336-363-5001

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

THE GREYSTONE INN
2663 ROARING GAP DR.
ROARING GAP NC, NC, 28668