



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10204-17-3699
State Number
10680

EQUIPMENT INSPECTED

State Number: 10680	Type of Unit: Passenger	Floor to Floor: 1 to 6
Capacity: 2500	Manuf: ASHEVILLE	Speed: 150
Landings: 6	Installed: 03/01/1984	Rope Size:
Volts: 208	Complied: 01/12/2007	Entrances: 1
OWNER	OCCUPANT	
AMBICA LLC	HOLIDAY INN	
PO BOX 2470	435 SMOKEY PARK HWY	
CANDLER, NC, 28715	ASHEVILLE, NC, 28806	

INSPECTION INFORMATION

Inspection Date 07/23/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

2.27.1.1.2 Put the in car emergency telephone in proper working order.

Items must be corrected by: 08/22/2010

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jackie Chambers 828-418-1123

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

AMBICA LLC
PO BOX 2470
CANDLER, NC, 28715