

## N C Department of Labor Elevator Bureau 1101 Mail Service Center, Raleigh, NC 27699-1101

## INSPECTION REPORT

IMPORTANT: Always use State Number in any correspondence relating to your equipment www.nclabor.com/elevator.htm 919-707-7927

Report Number 10204-48-0050 State Number 15263

EQUIPMENT INSPECTED				
State Number: 15263  Capacity: 2100  Landings: 3  Volts: 208  OWNER  CASWELL PARTNERSHIP  OCEAN GREEN LANE  CASWELL BEACH, NC, 28465		1/1993	Floor to Floor: Speed: 125 Rope Size: Entrances: 1	G to 2
		OCCUPANT OCEAN GREENS BLDG #3 59-62 FOX FIRE LN. CASWELL BEACH, NC, 28465		
	IN	NSPECTION INFORMATION		
Inspection Date 07/23/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
		VIOLATIONS		
2.14.7.1.4 8.6.4.7.1	Put the car top light in working of Clean the elevator pit.	order.		
Items must be corrected by Notify the Elevator Bureau in complainace with current code Violations pointed out to: UN	writing on Corrected Violations Form s.	when the following corrections	_	bring your equipment into
	To make changes to the invoice mailing address please call: 919-733-0372			
THIS IS NOT AN INVOICE	An invoice will be mailed to:	CASWELL PARTNERS OCEAN GREEN LANE CASWELL BEACH, NO	SHIP	