



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10208-8-1858
State Number
26637

EQUIPMENT INSPECTED

State Number: 26637	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: VERTICAL EX	Speed: 80
Landings: 3	Installed: 03/04/2009	Rope Size:
Volts: 208	Complied: 03/04/2009	Entrances: 1

OWNER

ANSON COUNTY GOVERNMENT
101 S GREENE STREET
WADESBORO, NC, 28170

OCCUPANT

ANSON COUNTY ADMIN OFB
101 S GREENE STREET
WADESBORO, NC, 28170

INSPECTION INFORMATION

Inspection Date 07/27/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 8 - Burris	County ANSON
-------------------------------	----------------------------	---------------------------------	-------------------------	-----------------

4

VIOLATIONS

Elevator Name: #1 PASSENGER ELEVATOR

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: REP- TORY FERRARO

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ANSON COUNTY GOVERNMENT
101 S GREENE STREET
WADESBORO, NC, 28170