



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10209-12-2542
State Number
17537

EQUIPMENT INSPECTED

State Number: 17537	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 3	Installed: 06/22/1998	Rope Size:
Volts: 208	Complied: 05/27/2003	Entrances: 1
OWNER	OCCUPANT	
CASPN ELDERLY HOUSING	CASPN ELDERLY HOUSING	
PO BOX 609	945 S CHURCH ST	
ASHEBORO, NC, 27204-0609	ASHEBORO, NC, 27203	

INSPECTION INFORMATION

Inspection Date 07/28/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 12 - Essick	County RANDOLPH
-------------------------------	----------------------------	---------------------------------	--------------------------	--------------------

76

VIOLATIONS

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Margret Trogdon Asheboro Hse Auth, 336 629 4146

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CASPN ELDERLY HOUSING
PO BOX 609
ASHEBORO, NC, 27204-0609