



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10214-16-312
State Number
24439

EQUIPMENT INSPECTED

State Number: 24439	Type of Unit: Passenger	Floor to Floor: P to 3
Capacity: 2500	Manuf: TKE	Speed: 125
Landings: 4	Installed: 01/10/2007	Rope Size: 0
Volts: 230	Complied: 01/10/2007	Entrances: 2

OWNER

DIXON & MEEKINS
103 EAST 8TH ST
NAGS HEAD, NC, 27959

OCCUPANT

DAY BEACON
326 E. WATER STREET
BELLHAVEN, NC, 27810

INSPECTION INFORMATION

Inspection Date 08/02/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

7

VIOLATIONS

2.2.5.1 Put the pit lights in proper working order.

Items must be corrected by: 08/22/2010

Elevator Name: D

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: David Maintenance and Grounds

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

DIXON & MEEKINS
103 EAST 8TH ST
NAGS HEAD, NC, 27959