



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**10214-17-0152**  
State Number  
**H1777**

EQUIPMENT INSPECTED

|                             |                              |                        |
|-----------------------------|------------------------------|------------------------|
| State Number: <b>H1777</b>  | Type of Unit: Hand Lift      | Floor to Floor: 1 to 2 |
| Capacity: 750               | Manuf: AEC                   | Speed: 12              |
| Landings: 2                 | Installed: 08/31/2006        | Rope Size: 0           |
| Volts: 115                  | Complied:                    | Entrances: 2           |
| OWNER                       | OCCUPANT                     |                        |
| ASHEVILLE BUNCOMBE TECH COL | HAYNES SMALL BUSINESS CENTER |                        |
| 1459 SAND HILL ROAD         | 1459 SAND HILL ROAD          |                        |
| CANDLER, NC, 28715          | CANDLER, NC, 28715           |                        |

INSPECTION INFORMATION

|                               |                            |                                 |                         |                    |      |
|-------------------------------|----------------------------|---------------------------------|-------------------------|--------------------|------|
| Inspection Date<br>08/02/2010 | Type Inspection<br>Routine | Certificate Status<br>Re-issued | Inspector<br>17 - White | County<br>BUNCOMBE | 11 A |
|-------------------------------|----------------------------|---------------------------------|-------------------------|--------------------|------|

VIOLATIONS

A18.1 Provide top floor door to self-close fully from any position.

Items must be corrected by: 09/01/2010

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: EDDIE DAVIS 828-254-1921

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ASHEVILLE BUNCOMBE TECH COL  
1459 SAND HILL ROAD  
CANDLER, NC, 28715