N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10214-48-1896
State Number
21563

EQUIPMENT INSPECTED

State Number: **21563**	Type of Unit: Passenger	Floor to Floor: 3 to 2
Capacity: 3500	Manuf: OTIS	Speed: 150
Landings: 1	Installed: 05/27/2003	Rope Size:
Volts: 208	Complied: 06/03/2003	Entrances: 0

OWNER
SEA TRAIL CORPORATION
279 CLUBHOUSE ROAD
SUNSET BEACH, NC, 28468

OCCUPANT
SEA TRAIL CAMPION #37
140 AVIAN DR.
SUNSET BEACH, NC, 28468

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
08/02/2010	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

2.27.1.1.2	Put the in car emergency telephone in proper working order.
N/A	PROVIDE MISSING CEILING PARTITION.

Items must be corrected by: 08/12/2010

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
SEA TRAIL CORPORATION
279 CLUBHOUSE ROAD
SUNSET BEACH, NC, 28468