N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10228-36-4951
State Number
27484

EQUIPMENT INSPECTED

State Number: **27484**
Capacity: 2500
Landings: 2
Volts: 208

Type of Unit: Passenger
Manuf: OTIS
Installed:
Complied:

Floor to Floor: 1 to 2
Speed: 100
Rope Size:
Entrances: 1

OWNER
COX TOYOTA
DANBROOK ROAD
BURLINGTON, NC, 27215

OCCUPANT
COX TOYOTA
DANBROOK ROAD
BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
08/16/2010	New	Issued	36 - Kirkman	ALAMANCE

1

VIOLATIONS

THIS UNIT IS IN COMPLIANCE THIS DATE 9/16/2010

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Joe

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
COX TOYOTA
DANBROOK ROAD
BURLINGTON, NC, 27215