N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10229-48-2162
State Number
23405

EQUIPMENT INSPECTED

State Number: **23405**	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 3500	Manuf: OTIS	Speed: 150
Landings: 3	Installed: 10/12/2005	Rope Size:
Volts: 208	Complied: 10/12/2005	Entrances: 2

OWNER
THE RED APPLE GROUP, LLC
712 VILLAGE ROAD
SHALLOTTE, NC, 28470

OCCUPANT
SHALLOTTE OFFICE BUILDING
712 VILLAGE ROAD, SW
SHALLOTTE, NC, 28470

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
08/17/2010	Routine	Re-issued	48 - Martin	BRUNSWICK	10

VIOLATIONS

n/a No violations found

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: TAMMY TRIPLETT - KESKY Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
THE RED APPLE GROUP, LLC
712 VILLAGE ROAD
SHALLOTTE, NC, 28470