



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10231-16-2528
State Number
25676

EQUIPMENT INSPECTED

State Number: 25676	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 06/16/2008	Rope Size: 0
Volts: 208	Complied:	Entrances: 1
OWNER	OCCUPANT	
CROSS RIVER DEVELOPERS LLC	GEORGE TOWNE OFFICE BLDG	
P O BOX 4	155 N MARKET ST	
WASHINGTON, NC, 27889	WASHINGTON, NC, 27889	

INSPECTION INFORMATION

Inspection Date 08/19/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

7

VIOLATIONS

- 8.6.11.1 Provide an updated monthly fire service log indicating proper Phase 1 and 2 operation and make available upon request the authority having jurisdiction.
- 8.6.1.4.1[a] Properly document maintenance records
- 8.11.3.2.1 Provide the annual relief valve and system pressure test.

Items must be corrected by: 09/18/2010

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Norman Koestline

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CROSS RIVER DEVELOPERS LLC
P O BOX 4
WASHINGTON, NC, 27889