



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**10236-48-0480**  
State Number  
**23726**

EQUIPMENT INSPECTED

State Number: <b>23726</b>	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: TKE	Speed: 50
Landings: 4	Installed: 04/11/2006	Rope Size:
Volts: 230	Complied: 04/11/2006	Entrances: 1
OWNER	OCCUPANT	
OCEAN WALK HOA % BEC MGMT	OCEAN WALK CONDO #3	
1600 MORGANTOWN RD	105 SE 58TH STREET	
PINEHURST, NC, 28374	OAK ISLAND, NC, 28465	

INSPECTION INFORMATION

Inspection Date 08/24/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.27.3.1	Put the Phase I fire service feature in proper working order.
2.14.7.1.4	Put the car top light in working order.
8.6.4.9	Clean the car top of all debris.

Items must be corrected by: 09/13/2010

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

OCEAN WALK HOA % BEC MGMT  
1600 MORGANTOWN RD  
PINEHURST, NC, 28374