



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10242-16-0880
State Number
H295

EQUIPMENT INSPECTED

State Number: H295	Type of Unit: Hand Lift	Floor to Floor: 1 to 2
Capacity: 500	Manuf: CHENEY	Speed: 12
Landings: 2	Installed: 03/02/1990	Rope Size: 0
Volts: 110	Complied: 03/02/1990	Entrances: 2

OWNER
BEAUFORT COUNTY SCHOOLS
321 SMAW RD
WASHINGTON, NC, 27889

OCCUPANT
WASHINGTON HIGH SCHOOL
400 SLATE STONE ROAD
WASHINGTON, NC, 27889

INSPECTION INFORMATION

Inspection Date 08/30/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

7

VIOLATIONS

2.6.6.1 Put the car lights in proper working order.

Items must be corrected by: 09/29/2010

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Patti Barnes

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BEAUFORT COUNTY SCHOOLS
321 SMAW RD
WASHINGTON, NC, 27889