



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10253-48-1115
State Number
19913

EQUIPMENT INSPECTED

State Number: 19913	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 06/29/2001	Rope Size: .
Volts: 208	Complied: 07/03/2001	Entrances: 2
OWNER	OCCUPANT	
NCDOT	NCDOT WILMINGTON BRIDGE MAINT FAC	
25 OLD RIVER RD	25 OLD RIVER RD	
LELAND, NC, 28451	LELAND, NC, 28451	

INSPECTION INFORMATION

Inspection Date 09/10/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

n/a No violations found

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: MANAGEMENT

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

NCDOT
25 OLD RIVER RD
LELAND, NC, 28451