



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10253-48-2974
State Number
24116

EQUIPMENT INSPECTED

State Number: 24116	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 10/05/2006	Rope Size: 0
Volts: 208	Complied: 10/05/2006	Entrances: 1
OWNER	OCCUPANT	
LOGAN HOMES	LOGAN OFFICE BLDG	
60 GREGORY ROAD - SUITE 1	60 GREGORY ROAD	
BELVILLE, NC, 28451	BELVILLE, NC, 28451	

INSPECTION INFORMATION

Inspection Date 09/10/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.1.4.2 The maintenance records shall be available to the elevator personnel. PROVIDE MTCE. RECORDS IN MOTOR ROOM.

Items must be corrected by: 10/10/2010

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: MANAGEMENT

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

LOGAN HOMES
60 GREGORY ROAD - SUITE 1
BELVILLE, NC, 28451